



P.O. Box 2101  
Ikaluktutiak, NU X0B 0C0  
☎ 867-983-4625  
📠 867-983-4626

Hamlet's reliance on diesel fuel for electricity. Project activities include: Installation and operation of up to ten wind turbines with a combined installed capacity of up to 1,000 kW located about 4.5 km south of the Sanikiluaq Airport; Upgrading an existing community trail to the Project site access road; Installation of a 5 km transmission line corridor that closely aligns with the access road when possible; A microgrid controller platform, and a BESS near the Qulliq Energy Corporation (QEC) power plant in town. The current project configuration recommendation consists of 1,000 kW wind energy and 500 kWh battery energy storage system.

2. Location: Qikiqtani [Sanikiluaq]

A complete description of the project proposal reviewed by the NPC can be accessed online using the link below.

The Nunavut Planning Commission (NPC) has determined that this project proposal is outside the area of an applicable regional land use plan. The project proposal requires screening by the Nunavut Impact Review Board (NIRB) because it does not belong to a class of exempt works or activities set out in Schedule 12-1 of the Nunavut Agreement.

By way of this letter, the NPC is forwarding the project proposal to the NIRB for screening. Project materials are available at the following address:

<https://lupit.nunavut.ca/portal/project-dashboard.php?appid=149782&sessionid=>

This decision applies only to the above noted project proposal as submitted. Proponents may not carry out projects and regulatory authorities may not issue licenses, permits and other authorizations in respect of projects if a review by the NPC is required.

If you have any questions, please do not hesitate to contact me at (867) 979-3444.

Sincerely,



Goump Djalogue, MCIP/RPP  
Manager of Planning and Implementation  
Nunavut Planning Commission